



MEGHALAYA STATE ELECTRICITY REGULATORY COMMISSION SHILLONG

Front Block Left Wing, 1st Floor, New Administrative Building,
Lower, Lachumiere, Shillong, Meghalaya 793001

PRE-PUBLICATION NOTIFICATION

Dated: 1st October 2026

MSERC/DRE-REGULATION/2026/... : In exercise of the power conferred under Sections 61, 66, 86 (1) (e) and 181 of the Electricity Act 2003 (36 of 2003) read with Regulation 15.2 and 15.3 of the Meghalaya State Electricity Regulatory Commission (Grid Interactive Distributed Renewable Energy Sources) (2 of 2026) Regulations, 2026 and all other power enabling it in this behalf, the Meghalaya State Electricity Regulatory Commission, hereby **proposes to amend** the Meghalaya State Electricity Regulatory Commission (Grid Interactive Distributed Renewable Energy Sources) (2 of 2026) Regulations, 2026 (herein referred to as the “Principal Regulations”) namely;

1. Short title and commencement

- 1.1. These regulations shall be called the Meghalaya State Electricity Regulatory Commission (Grid Interactive Distributed Renewable Energy Sources) (2 of 2026) (First Amendment) Regulations, 2026;
- 1.2. These regulations shall come into force from the date of their publication in the Official Gazette of the Government of Meghalaya.

2. Amendment to Chapter-4: Metering Mechanisms, Eligible Consumers and Allowed DRES Capacities

Sub-Clause 4.1.2 of Regulation 4.1 of the Principal Regulation is amended as hereunder:

4.1 Net Metering

- 4.1.2 The minimum capacity of DRES that can be set up under net metering mechanism shall be 1 kW, while the maximum capacity shall not exceed the sanctioned load or contract demand of the prosumer or 500 kW, whichever is lower:

Provided that DRES capacity of more than 10 kW and above, shall have to be equipped with hybrid inverter & battery energy storage system with a

minimum storage capacity of 20% of the daily energy generation potential of the plant.

Provided that in the event a prosumer had received approval of the DISCOM under the provisions of the Meghalaya State Electricity Regulatory Commission (Rooftop Solar Grid Interactive Systems Based on Net Metering) (First Amendment) Regulations, 2015 (1 of 2025), prior to the Notification of the Meghalaya State Electricity Regulatory Commission (Grid Interactive Distributed Renewable Energy Sources) (2 of 2026) Regulations, 2026 for a capacity beyond 500 KW, the capacity as approved shall be permitted, with or without battery storage.

The Table at Regulation 4.7 shall be read with the aforementioned proviso.

(By order of the Commission)

Sd/-

E. Slong

Secretary